

SECTION 07 84 00
FIRESTOPPING PENETRATIONS, JOINTS AND PERIMETER FIRE
CONTAINMENT

PART 1 GENERAL

1.00 RELATED DOCUMENTS

- A. The BIDDING REQUIREMENTS, CONTRACTING REQUIREMENTS, and applicable parts of DIVISION 1 - GENERAL REQUIREMENTS, as listed in the Table of Contents, shall be included in and made a part of this Section.

1.01 SUMMARY

- A. Provide firestop systems consisting of a material, or combination of materials installed to retain the integrity of fire-rated construction by maintaining an effective barrier against the spread of flame, smoke, and/or hot gases through penetrations, blank openings, construction joints, or at perimeter fire containment in or adjacent to fire-rated barriers in accordance with the requirements of the Building Code for this project.
- B. Firestop systems shall be used in locations including, but not limited to, the following:
1. Penetrations through fire-resistance-rated floor and roof assemblies requiring protected openings including both empty openings and openings that contain penetrations.
 2. Penetrations through fire-resistance-rated wall assemblies including both empty openings and openings that contain penetrations.
 3. Membrane penetrations in fire-resistance-rated wall assemblies where items penetrate one side of the barrier.
 4. Joints in fire-resistance-rated assemblies to allow independent movement.
 5. Perimeter Fire Barrier System between a rated floor/roof and an exterior wall assembly.
 6. Joints, through penetrations and membrane penetrations in Smoke Barriers and Smoke Partitions.

1.02 RELATED WORK

- A. Examine Contract Documents for requirements that affect Work of this Section. Other Specification Sections that relate directly to Work of this Section include, but are not limited to:
1. Division 3 - CAST-IN-PLACE CONCRETE; Concrete work
 2. Division 4 - UNIT MASONRY
 3. Division 5 - EXPANSION, CONTROL, and SEISMIC JOINTS
 4. Division 7 - THERMAL AND MOISTURE PROTECTION
 5. Division 8 - GLASS, GLAZING AND METAL CURTAIN WALL SYSTEMS
 6. Division 9 - GYPSUM WALLBOARD
 7. MasterFormat 1995 - Division 15 - MECHANICAL
 8. MasterFormat 1995 - Division 16 - ELECTRICAL, LIGHTING, POWER, ALARMS and COMMUNICATIONS
 9. MasterFormat 2004 – Division 21 Fire Suppression

10. MasterFormat 2010 – Division 22 - Plumbing
11. MasterFormat 2010 – Division 23 - Heating, Ventilation, and Air Conditioning, (HVAC)
12. MasterFormat 2010 – Division 26 – Electrical
13. MasterFormat 2010 – Division 27 – Communications
14. MasterFormat 2010 – Division 28 – Electronic Safety and Security
15. MasterFormat 2010 – Division 8 - Openings

1.03 REFERENCES

- A. Comply with applicable requirements of the following standards. Where these standards conflict with other specified requirements, the most restrictive requirement shall govern.
 1. American Society for Testing and Materials (ASTM).
 - a) E 84 Test Method for Surface Burning Characteristics of Building Materials
 - b) E 119 Test Method for Fire Tests of Building Construction and Materials
 - c) E 136 Test Method for Behavior of Materials in a Vertical Tube Furnace at 750F
 - d) E 814 Fire Tests of Through-Penetration Fire Stops
 - e) E 1399 Cyclic Movement and Measuring Minimum and Maximum Joint Widths
 - f) E 1966 Test Method for Resistance of Building Joint
 - g) E 2174 Standard Practice for On-Site Inspection of Installed Fire Stops
 - h) E 2393 Standard Practice for On-Site Inspection of Installed Fire Stop Joint Systems
 - i) E 2307 Standard Test Method for Determining the Fire Endurance of Perimeter Fire Barrier Systems Using the Intermediate-Scale, Multi Story Test Apparatus (ISMA)
 2. Factory Mutual (FM) Approvals:
 - a) FM Approval Standard of Firestop Contractors – Class 4991
 3. Firestop Contractors International Association (FCIA):
 - a) MOP – FCIA Firestop Manual of Practice
 4. International Firestop Council (IFC):
 - a) Ref. 1 Recommended IFC Guidelines for Evaluating Firestop Engineering Judgments (April 2001)
 - b) Ref. 2 Inspectors Field Pocket Guide
 5. National Fire Protection Association (NFPA):
 - a) NFPA 70 - National Electric Code
 - b) NFPA 101 - Life Safety Code
 - c) NFPA 221 - Fire Walls and Fire Barriers (preliminary to be released)
 - d) NFPA 251 - Fire Tests of Building Construction and Materials
 6. Underwriters Laboratories, Inc. (UL):
 - a) UL Qualified Firestop Contractor Program
 - b) UL 263 Fire Tests of Building Construction and Materials
 - c) UL 723 Surface Burning Characteristics of Building Materials
 - d) UL 1479 Fire-Tests of Through-Penetration Fire Stops
 - e) UL 2079 Tests for Fire Resistance of Building Joint Systems

1.04 SYSTEM PERFORMANCE REQUIREMENTS

- A. Penetrations: Provide and install firestopping systems that are produced to resist the spread of fire, and the passage of smoke and other gases according to requirements indicated, including but not limited to the following:
 - 1. Firestop all penetrations passing through fire resistance rated wall and floor assemblies and other locations as indicated on the drawings.
 - 2. Provide and install complete penetration firestopping systems that have been tested and approved by third party testing agency.
 - 3. F - Rated Through-Penetration Firestop Systems: Provide through-penetration firestop systems with F ratings indicated, as determined per ASTM E 814, but not less than one hour or the fire-resistance rating of the construction being penetrated.
 - 4. T - Rated Through-Penetration Firestop Systems: Provide firestop systems with T ratings, in addition to F ratings, as determined per ASTM E 814, where indicated..
 - 5. L – Rated Through-Penetration Firestop Systems: Provide firestop systems with L ratings, in addition to F and T ratings, as determined per UL 1479, where indicated.
 - 6. **(Optional)** W – Rated Through-Penetration Firestop Systems: Provide firestop systems with W Water Resistance ratings, in addition to F, T and L ratings, as determined per UL 1479, where indicated.
- B. Perimeter Fire Containment Systems: Provide interior perimeter joint systems with fire-resistance ratings indicated, as determined per ASTM E 2307, but not less than the fire-resistance rating of the floor construction.
- D. Fire-Resistive Joints: Provide joint systems with fire-resistance ratings indicated, as determined per UL 2079, but not less than the fire-resistance rating of the construction in which the joint occurs.
- E. For firestopping exposed to view, traffic, moisture, and physical damage, provide firestop systems for these conditions that meet conditions expected as communicated through construction documents.
- F. Where there is no specific third party tested and listed, classified firestop system available for a particular firestop configuration, the firestopping contractor shall obtain from the firestop manufacturer, an Engineering Judgment (EJ) or Equivalent Fire Resistance Rated Assembly (EFRRA) for submittal.

1.05 SUBMITTALS

- A. Submit Manufacturers Product Data Sheets for each type of product selected. Certify that Firestop Material shall be asbestos free and complies with local regulations.
 - 1. Certification by firestopping manufacturer that products supplied comply with local regulations controlling use of volatile organic compounds (VOC's) and are nontoxic to building occupants.
- B. Submit system design listings, including illustrations from a qualified testing and inspection agency that is applicable to each firestop configuration

1. Where there is no specific third party tested and classified Firestop System available for particular firestop configuration, the firestopping contractor shall obtain from the firestop manufacturer an Engineering Judgment (EJ) or Equivalent Fire Resistance Rated Assembly (EFRRA) for submittal.

C. Submit contractor qualifications as noted in “Quality Assurance” article.

1.06 QUALITY ASSURANCE

A. Fire-Test-Response Characteristics: Provide firestopping System Design Listing by a testing and inspection agency in accordance with the appropriate ASTM Standard(s) per article 1.04. A qualified testing and inspection agency may be UL, FM Research, Intertek Testing Services, Omega Point Laboratories (OPL) or another agency performing testing and follow-up inspection services for firestop materials that is acceptable to the authority having jurisdiction.

B. Contractor Qualifications: Acceptable installer firms shall be:

1. FM Approved in accordance with FM Standard 4991 – Approval of Firestop Contractors, or.
2. UL Qualified Firestop Contractor, or;
3. Firestop Contractors International Association Contractor Member in good standing.
4. Licensed by the State or local authority, where applicable.
5. Shown to have successfully completed not less than 5 comparable scale projects.

C. Single Source Responsibility: Obtain firestop systems for each kind of penetration and construction condition indicated from a single primary firestop systems manufacturer.

1. Materials of different manufacture than allowed by the tested and listed system shall not be intermixed in the same firestop system or opening.
2. Tested and listed, classified firestop systems are to be used. If another manufacturer has a tested and listed system, then that system shall be used prior to an Engineering Judgment (EJ) or Equivalent Fire Resistance Rated Assembly (EFRRA).

D. Field Constructed Mockup: Prior to installing firestopping, erect mockups for each different firestop system indicated to verify selections made and to demonstrate qualities of materials and execution. Build mockups to comply with the following requirements, using materials indicated for final installations.

1. Locate mockups on site in locations indicated or, if not indicated, as directed by Architect. Include mockup for each type of system.
2. Notify Architect in advance of the dates and times when mockups will be installed.
3. Obtain Architect and AHJ’s acceptance of mockups before start of Work.
4. Retain and maintain mockups during construction in an undisturbed condition as a standard for judging completed unit of Work. Accepted mockups in an undisturbed condition at time of Substantial Completion may become part of completed unit of Work.

1.07 DELIVERY, STORAGE, AND HANDLING

A. Deliver firestopping products to Project site in original, unopened containers or packages with intact and legible manufacturers' labels identifying product and manufacturer.

- B. Store and handle firestopping materials in accordance with manufacturers written instructions.

1.08 PROJECT CONDITIONS

- A. Environmental Conditions: Install firestopping in accordance with manufacturers written instructions.
- B. Ventilation: Ventilate per firestopping manufacturers' instructions or Material Safety Data Sheet (MSDS)

1.09 SEQUENCING AND SCHEDULING

- A. Project coordination is essential to inform and educate all the parties involved with the firestopping process of their role and how they can affect firestopping on the project. A pre-construction meeting shall be scheduled and required for all parties involved prior to the start of construction.

1.10 ENVIRONMENTAL REGULATIONS

- A. All materials shall be asbestos free and comply with local VOC Regulations.
- B. If required, hazardous disposal of firestop materials shall be strictly observed as noted on the individual MSDS.

PART 2 PRODUCTS

2.01 FIRESTOPPING, GENERAL

- A. Systems listed by approved testing agencies, as identified in part 1 above, may be used, providing they conform to the construction type, penetrant type, annular space requirements and fire rating involved in each separate instance.
- B. Manufacturer of firestop products shall have been successfully producing and supplying these products for a period of not less than 3 years, and be able to show evidence of at least 10 projects where similar products have been installed and accepted.
- C. Firestop products produced by FCIA Manufacturer Members in good standing.
 - a. 3M Fire Protection Products
 - b. BALCO, Inc.
 - c. HILTI, Inc.
 - d. Specified Technologies, Inc.
 - e. Thermal Ceramics, Inc.
 - f. Thermafiber, Inc.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine substrates and conditions, with Installer present, for compliance with requirements for opening configurations, penetrating items, substrates, and other conditions affecting performance of firestopping. Notify the responsible party or parties of any unsatisfactory conditions. Do not proceed with installation until unsatisfactory conditions have been corrected.

3.02 PREPARATION

- A. Cleaning & Preparation: Clean and prepare surfaces as recommended by firestop system manufacturer.
- B. Verify that system components are clean, dry, and ready for installation.
- C. Verify that field dimensions are as shown on the Drawings, tested and listed, classified systems, Engineering Judgments, EFRRA's and as recommended by the manufacturer.

3.03 INSTALLING PENETRATION FIRESTOPS

- A. General: Comply with the "System Performance Requirements" article in Part 1 and the through-penetration firestop manufacturer's installation instructions and drawings pertaining to products and applications indicated.
 - 1. Coordinate with other trades to assure that all pipes, conduit, cable, and other items, which penetrate fire rated construction, have been permanently installed prior to installation of firestop assemblies.
 - 2. Schedule the work to assure that partitions and all other construction that conceals penetrations are not erected prior to the installation of firestop and smoke seals.
- B. Install packing/backing/forming materials and other accessories in accordance with manufacturers written instructions, tested and listed, classified systems
- C. Install fill, void and cavity materials for through-penetration firestop systems by proven techniques as recommended by the manufacturer, tested and listed, classified system and tooled to produce the following results:
 - 1. Clean surfaces as recommended by manufacturers' written instructions.
 - 2. Completely fill voids and cavities formed by openings, forming materials, accessories, and penetrating items.
 - 3. Install materials so they contact and adhere to substrates formed by openings and penetrating items.
 - 4. Finish to produce smooth, uniform surfaces as recommended by manufacturer's written instructions and tested and listed, classified system requirements.

3.04 INSTALLING FIRESTOP JOINT SYSTEMS

- A. General: Comply with the "System Performance Requirements" article in Part 1 and with the firestop manufacturer's installation instructions and drawings pertaining to products and applications indicated.
 - 1. Install joint forming materials to provide support of firestop materials during application and at the position required to produce the cross-sectional shapes and depths of installed firestop

material relative to joint widths that allow optimum sealant movement capability and develop fire-resistance rating required.

- B. Install tested and listed, classified systems and non-tested engineering judgments, EFRRA's that result in firestop materials:
 - 1. Directly contacting and fully wetting joint substrates.
 - 2. Completely filling recesses provided for each joint configuration,
 - 3. Providing uniform, cross-sectional shapes and depths relative to joint width that optimize movement capability and meet tested and listed system requirements.
- C. Tool non-sag firestop materials immediately after their application and prior to the time skinning or begins. Form smooth, uniform beads of configuration indicated or required to:
 - 1. produce fire-resistance rating
 - 2. to eliminate air pockets
 - 3. to ensure contact and adhesion with sides of joint.

3.05 INSTALLING PERIMETER FIRE BARRIER SYSTEMS

- A. General: Comply with "System Performance Requirements" article in Part 1 and with the firestop manufacture's installation and drawings pertaining to products and applications indicated.
- B. Install metal framing, curtain wall insulation, mechanical attachments, safing materials and other firestop system components as applicable within the system design.

3.06 FIELD QUALITY CONTROL

- A. Provide either of the following:
 - a. CERTIFICATE OF CONFORMANCE – Firestopping shall be installed by an FM 4991 Approved Firestop Contractor and/or UL Qualified Firestop Contractor. The installer shall issue to AHJ or Owner a Certificate of Conformance confirming that the work has been carried out in accordance with specifications.

...AND/OR...
 - b. INSPECTION – Independent inspection agency employed and paid by owner, will examine penetration firestopping in accordance with ASTM E – 2174, "Standard Practice for On-Site Inspection of Installed Fire Stops and ASTM E-2393, "Standard Practice for On-Site Inspection of Installed Fire Stop Joint Systems.

[NOTE FOR SPECIFIER: Chapter 17 of the 2012 International Building Code requires ASTM E 2174-09 and ASTM E 2393-09 for buildings 75' and higher, and Occupancy Category III or IV buildings constructed in accordance with Section 1604.5.]

3.07 CLEANING

- A. Clean off excess fill materials and sealants adjacent to openings and joints as work progresses. Use methods and cleaning materials approved by manufacturers of firestopping products and or assemblies in which openings and joints occur.

- B. Protect firestopping during and after curing period from contact with contaminating substances. If damage caused by others, owner and general contractor to instruct firestop contractor to make appropriate repairs and charge to appropriate trades.

END OF SECTION 07 84 00

**Specification is reprinted from Appendix H, "FCIA Manual of Practice", Page App. H, 1-7 - FCIA
Specification – Revision No. 7, 01-27-2011**