ASHE Region 2 Radisson Valley Forge

May 13, 2014



"DIIM"

- Barriers are for Safety DIIM
 - Properly *Designed* and Specified
 - Tested and Listed Systems Directories, Tables
 - Professional *Installation* Companies
 - Properly *Inspected* Commissioned, Companies
 - Maintained
 - NFPA 101 2000 (TJC, CMS)
 - International Fire Code IFC 2012 Annually (Local)

"TOTAL FIRE PROTECTION"

- Effective Compartmentation
 - Fire Barriers, Fire Walls/Floors, Smoke Barriers
 - Firestopping, Fire Dampers, Swinging and Rolling Fire Doors, Fire Rated Glazing
- Detection & Alarm Systems
- Sprinkler Suppression Systems
- Education & Egress—
 - Building Owners & Managers, Building Occupants and Firefighters









Building & Fire Code Requirements

- Continuous Fire Resistance
 - Walls / Horizontal Assemblies Continuity
 - Firestop Products Become Firestop Systems
 - Penetrations
 - Joints Head /Bottom of Wall Perimeter Joints
 - Fire & Smoke Damper Duct Systems
 - Fire Doors and Hardware Systems
 - Rolling & Swinging
 - Fire Rated Glazing

Continuity

Effective Compartmentation Features











Continuity SYSTEMS

- Products Become Systems Through Testing
 - Fire Barriers ASTM E 119, NFPA 251 & UL 263
 - Firestopping ASTM E 814 / UL 1479, ULC-S-115,
 UL 2079, E-2307 as the test method..."
 - Dampers UL 555, UL 555S
 - Doors UL 10B, 10C
 - Fire Rated Glazing UL 9
 - Testing = Suitability statement for use of a product in a specific <u>system</u> application

Products become Systems Hose Stream = Shock Test





Barrier Continuity Products become SYSTEMS

- Fire Rated Systems Directories
 - UL Fire Resistance Directory
 - Intertek
 - FM Approvals


Systems Selection & Analysis...Not as easy as it looks...






Intertek		Product Directori	es	
Warnock	Hersey M	ark Directory		
Enter Search	Terms:			
Company	Nothing Serected			
Listing Section	FIRESTOP SYSTEMS			
CSI Code	Nathing select	ed		
Standard	Nothing selected			
Reyword Test	Search Secon			
Company		Title	Standard	
3M (Minneagte Mining and Menufesturine)		SM Fire Barrier Duts Wrep 815	ASTM 2814; 350 8944	-
2M (Minnesote Mining and Menufacturing)		SM Fire Berrier Duct Wrep 615-	ASTM CS18: ASTM E110: ASTM E130: ASTM E2330: ASTM E814: ICC-ES AC101: ISO 8944	100
3M (Minnesots Mining and Menufecturing)		SM Fire Berrier** 1000 NS Silicone Joint Sealant	ASTM E1199; ASTM E2107; ASTM E2130; ASTM E814; ICC-E5 AC101; ISO 6944; UL 2079	
2M (Minnesote Mining and Manufacturing)		364 Fire Servier* 1003 St. Stricone Joint Sealant	ASTM E2307; ASTM E2336; ASTM E814; ICC-E5 AC101; ISO 6944; UL 2079	
3M (Minnesota Mining and Manufacturing)		SAF Fire Barrier* 2000 and 2003 Silicone Joint Sealant	ASTM ELLE, ASTM ERLE	
3M (Minnesota Mining and		SM Fire Barrier 2000- Shicone	ASTM EZBRE, ARTM EREA, ICC-ES	-

Barrier Continuity I – Installation – Listed Systems



I- Installation

Who's Responsible, How to Choose???




What Contractor Qualifications?

- FM 4991 Standard for the Approval of Firestop Contractors
- UL Qualified Firestop Contractors
- Other Industries...


• UNDERSTANDS ALL ABOUT SYSTEMS & DOCUMENTATION

Why Contractor Qualifications?

- Accountability
- Built right the first time...
- Documentation
- SYSTEMS Selection, Analysis
 - F, T, H, L, W
 - Tolerances Annular Space Sizes
 - Gap Sizes Undercuts Framing
 - Anchors Spacing Hardware
 - Closers Activation Sensors, more...



Installation & Inspection



I – Inspection – Options

Contractor Self Inspection

Verify Management System validity


• Manufacturer Inspection?

Does not exist ... Survey, maybe

Special Inspection/Commissioning


- Independent 3rd Party
- Destructive, Non Destructive
- Specified Frequency
- Inspection Agency Accreditation IAS AC 291

Compartmentation for Safety




SECTION B

M – Maintenance(& Management)



Firestop Maintenance

- Maintenance
 - Code Required
 - How??
- How to keep Track Barrier Management Initiatives
 Paper
 Software
 Labeling



National Fire Protection Association - NFPA 101-2012

- SECTION 4.5.8 Maintenance, Inspection, and Testing.
- 4.5.8.1 Whenever or wherever any device, equipment, system, condition, arrangement, level of protection, fire-resistive construction, or any other feature is required for compliance with the provisions of this Code, such device, equipment, system, condition, arrangement, level of protection, fire-resistive construction, or other feature shall thereafter be continuously maintained in accordance with applicable NFPA requirements or requirements developed as part of a performance-based design, or as directed by the AHJ. [101:4.6.12.1]

National Fire Protection Association - NFPA 101-2012

- 4.5.8.2 No existing life safety feature <u>shall be removed or</u> <u>reduced</u> where such feature is a requirement for new construction. [101:4.6.12.2]
- 4.5.8.3* Existing life safety features obvious to the public, if not required by the Code, shall be either maintained or removed. [101:4.6.12.3]
- 4.5.8.4 Any device, equipment, system, condition, arrangement, level of protection, fire-resistive construction, or any other feature requiring periodic testing, inspection, or operation to ensure its maintenance shall be tested, inspected, or operated as specified elsewhere in this Code or as directed by the AHJ. [101:4.6.12.4]
- 4.5.8.5 Maintenance, inspection, and testing <u>shall be performed under the supervision of a responsible person who shall ensure</u> that testing, inspection, and maintenance <u>are made at specified intervals</u> in accordance with applicable NFPA standards or as directed by the AHJ. [101:4.6.12.5]

International Fire Code Maintenance

SECTION 703
FIRE-RESISTANCE-RATED CONSTRUCTION



703.1 Maintenance. The required fire resistance rating of fire-resistance rated construction (including walls, fire stops, shaft enclosures, partitions, smoke barriers, floors, fire resistive coatings and sprayed fire resistant materials applied to structural members and fire resistive joint systems) **shall be maintained**. Such elements shall be **visually inspected by the owner annually** and properly repaired, restored or replaced when damaged, altered, breached or penetrated.

Openings made therein for the passage of pipes, electrical conduit, wires, ducts, air transfer openings, and holes made for any reason shall be protected with approved methods capable of resisting the passage of smoke and fire.

UAE Fire and Life Safety Code of Practice Maintenance & Management

Chapter 1, SECTION 21 Firestopping

<u>21.15.2</u> The required fire resistance rating of installed firestop systems shall be <u>visually inspected</u> by the owner or owner's inspection agency <u>annually.</u> Damaged, altered or breached firestop systems shall be properly repaired, restored or replaced to comply with applicable codes as per the guidelines of Civil defense.

21.15.3 Any new Openings made therein for the passage of through penetrants, shall be protected with approved firestop system to comply with applicable codes as per the guidelines of Civil defense.

National Fire Code of Canada

National Fire Code of Canada

- Division B Part 2, Building and Occupant Fire Safety

 2.2.1.2 Damage to Fire Separations where fire separations are damaged so as to affect their integrity, they shall be repaired so that the integrity of the fire separation is maintained...
- FCIA Manual of Practice Appendix, Maintenance
 FCIA recommends Barrier Management for Effective Compartmentation and Structural Protection


Includes Fire Dampers, Fire Doors...and Continuity



'When you're up to you're a__ in alligators, it's hard to remember you're there to drain the swamp.'




Barrier Management Begins when new construction ends...




- NEW Buildings Specifications Set Stage
 - SYSTEMS Expectations
 - As Built SYSTEMS
 - Testing
 - Installation
 - Inspection
- AS BUILT DOCUMENTATION IN SPECIFICATIONS


Now it's your building....



WHAT NEEDS TO BE MAINTAINED?

- Fire Resistive Wall Construction
- Fire Doors
- Fire Dampers
- Firestop Systems:
- Joint Systems
- Hot and Cold Water Piping
- Laboratory Waste
- Medigas Piping
- Pneumatic Tubing
- Sprinkler Piping
- Rigid Electrical Conduits
- Cable Trays
- BX Cables
- Low Voltage Cables
- and More....
 - Low Voltage!!!!





- Barrier Management
 - TJC # 1 & 2 Violations
 - Constant issues
 - Control?
 - Staff?
 - Attitude?



Barrier Management HUB

- A HUB must control all Action
 - C-Suite Execs
 - Construction In House & Outside
 - I-T Department In House & Outside
- The HUB is YOU!

Why Barrier Hub is YOU?

- YOU answer to...
 - The Joint Commission
 - CMS Inspectors
 - Building Official, Fire Marshal
 - Other AHJ's
 - C-Suite
 - Staff
 - Patients

- Barrier Management Policy Tool
- ASHE Member Healthcare Engineer & Director Communicates...
 - In House Construction & I-T Crews
 - Outside Contractors

Barrier Management Policy = Tool

- ASHE Member Healthcare Engineer & Director Communicates...
 - Rules of Engagement in Contracts
 - Internal Contracts
 - External Contracts
 - Pre Construction Meetings
 - Barrier Warnings Markings
 - Violation Consequences
 - Ongoing Management
 - Staff Education & Incentives

Barrier Management Policy Tool

- Rules of Engagement in Contracts
 - Internal Contracts -
 - In House Departments similar to Outside Contractors
 - External Contracts
 - AIA Contract
 - Marked Fire Smoke Barrier Actions
 - Barrier Permits
 - Documentation
 - Report

- Methods to Control
 - Paper, Pictures & Files
 - Electronic Pictures & Files
 - 'Custom'
 - 'Packages'


- Common Elements
 - Life Safety Drawings
 - Existing Conditions Documented
 - Ongoing Survey Records
 - Deficiency Reports
 - Systems Documentation Control, Retrieval

- Document & Control
- Fire Resistance Rated & Smoke Resistant
 - Barrier Walls, Floors
 - Firestop Systems Penetrations & Joints
 - Fire Doors Rolling & Swinging
 - Fire Rated Glazing
 - Fire/Smoke, Combination Dampers

- Electronic Best Practice Elements
 - Action Oriented
 - Projects Specifications
 - Ongoing Surveys FCIA RPPS 2010-1
 - Action Reminders
 - In Process Status
 - Record Retrieval




Sample Permit – Area







Permit No.: 2011-005 Demo Hospital Side 2: 3L1 Area (^) Side 1: 3C1 3C1/3L1 Compliance Status: LSR ID: LST-B1-03-007 Non-compliant Survey ID: LSR Group: Life Safety Details | Surveys | Photos | Floor Plan Diagrams LSR Deta... Latest Ph... Life Safety T... Life Safety Sub ... Letters LSR Count Status Detail Description Numbers Notes Firestopping Through Wall Through Wall Pe... | WL > 001 Non-com... Firestopping 1000-1999 Penetration - Firestop Firestopping Through Wall Compliant Through Wall Pe... WL 002 Firestopping 1000-1999 0 Penetration - Firestop Firestopping Firestopping Through Wall Pe... WL Compliant Through Wall 003 5000-5999 Penetration - Firestop Firestopping Compliant Through Wall Through Wall Pe... WL 004 Firestopping 3000-3999 1 EZ Path Penetration - Firestop < > Add New Life Safety Detail Entry Edit Selected Life Safety Detail Entry Save & Close Save & Add Another Delete Record Edit Save Cancel Edit Selected Permit Delete Selected Row Close Form Beta v1.3.13.9 Client: Life Safety Tracker Demo



- Pre Construction Meetings Education
 - Barrier Markings Mean...
 - Actions when at Barriers Required...
 - Permit required Above Ceiling, Barrier Hole...
 - Infection Control Rules
 - Healthcare facility Rules

- Barrier Warnings on ASSEMBLIES
- International Building Code 2009++





- Violation Consequences
 - In House -
 - 2 strikes & work reassignment to cleaning...
 - Others...
 - Outside Contractors
 - 2 strikes & not allowed to work above ceilings
 - Others...

- Incentives
 - Find Violators....
 - Staff Awards

- Ongoing Management
 - Engineering Staff Reviews
 - User Staff Reviews
 - Inside Construction
 - Outside Contractor

- Education Healthcare Staff Simple??
 - Fire Doors & Hardware Simple things...
 - Close & Latch
 - Holes in Door
 - Ladder = ?? Permit Sticker?
 - Fire Rated Walls Holes
 - Accidental
 - Workers

"TOTAL FIRE PROTECTION"

- Effective Compartmentation
 - Fire Barriers, Fire Walls/Floors, Smoke Barriers
 - Firestopping, Fire Dampers, Swinging and Rolling Fire Doors, Fire Rated Glazing
- Detection & Alarm Systems
- Sprinkler Suppression Systems
- Education & Egress—
 - Building Owners & Managers, Building Occupants and Firefighters









"DIIM"

- Barriers are for Safety DIIM
 - Properly *Designed* and Specified
 - Tested and Listed Systems Directories,
 - Professional *Installation* Companies
 - Properly *Inspected* Commissioned
 - *Maintained* Annually IFC 2012, NFPA 101, International Fire Code

Effective Compartmentation is a SYSTEM













Contacts

Firestop Contractors International Association Hillside, IL – +1-708-202-1108 - office Bill McHugh – bill @ fcia.org

Region 2 Symposium Radisson Valley Forge

May 13, 2014



• D

• D