

## The Approval Process for Firestop Contractors – FM Approvals<sup>®</sup> Approval Standard 4991

Member of the FM Global Group

Joseph Nunes Advance Engineer Materials Group

# Topics for Today's Discussion

- Definitions
- A description of the program
- The Approval process
- What exams are required and what are they like?
- What needs to be in a QA Manual?
- What are the audits like?
- How do I maintain the Approval?

- Approved Firestop Contractor
- Contractor
- Designated Responsible Individual (DRI)
- Learning Unit (LU)
- Surveillance Audit
- Re-examination

#### Approved Firestop Contractor

 A contractor who meets the requirements of FM Approval Standard 4991.

#### Contractor

 A business entity providing the services of installing firestop assemblies, systems and components.

- Designated Responsible Individual (DRI)
  - The contractor's employee who meets the criteria contained in FM Approval Standard 4991. The DRI shall provide oversight for the proper design selection, installation and transmission of information to field personnel. The DRI is also responsible for continuing to meet the criteria needed to maintain continued Approval within the firm.

### **Some Definitions**

- Learning Unit (LU)
  - Is a standard unit that we use to measure learning. One (1) LU is = one (1) hour of educational training. LUs can be obtained by attending or presenting at conferences, training programs (manufacturer or otherwise) and other educational settings related to firestopping, the construction industry, loss prevention, safety, fire containment, building codes or other areas acceptable to FM Approvals.

- Surveillance Audit
  - Is a mechanism used to ensure that the appropriate controls are in place and to verify that the contractor is conforming specific requirements as stated in their Approval Report and QA Manual. The audit shall occur at least annually. For Firestop Contractors, the auditor shall visit both the office and a job-site.

Re-examination

- a periodic requalification required of each DRI. Can be accomplished by written examinations or attainment of continuing education credits

- Purpose
- Method to qualify companies
- Assesses commitment to a QA program
- Ability to understand requirements of FCIA MOP and FM Approvals criteria
- Proper selection and installation of systems
- Marketing tool

- Purpose
  - To improve the performance and installation of firestop systems and components by examining and qualifying contractors who install such systems.

- Method to qualify companies
  - Assess the company's commitment to a QA program.
  - Ability of individuals to understand the requirements and restrictions/limitations of the FCIA MOP, FM criteria and design selection/installation.
  - Examine the contractor's training and education of its workforce.

- Assesses commitment to a QA program
  - Review the company's QA Manual and management's commitment to the manual.
  - Commitment to maintaining a documented and archived record keeping system for all installations.
  - Adherence to the manual, procedures and documentation via follow-up Surveillance Audits – both office and job-site.

- Ability to understand requirements of FCIA MOP and FM Approvals criteria
  - Assess DRI's knowledge by requiring passing score of 80 on two (2) separate exams
    - General Information
    - Design Selection

- Proper selection and installation of systems
  - Assess DRI's ability via written examination.
  - Review the contractor's written QA Manual.
  - Conduct initial Surveillance Audit
    - Conduct destructive examination of installations for conformance to the selected design criteria

- Marketing tool
  - Differentiate your company from the competition.
  - Placement of FM Approval Mark on installation labels.
  - Partnering with FM Global
    - Access to end users and local regulators

- Contact FM Approvals
- Submit an application for Approval
- Proposal by FM and project authorization
- Assess DRIs must take and pass DRI exams
- Submit a written QA Manual
- Office and job-site audits
- Issue documentation and listing

- Contact FM Approvals/Request an Application for Approval. Provide all contact information
  - Email to Information@FMApprovals.com
  - Application form-"application for new products"
  - Legal company name
  - Need a physical address
  - Contact name, phone and email

- Proposal and project authorization
  - FM engineer will review the information
    - The company must have been in the firestopping business for at least two (2) years
  - Generate a written cost proposal
  - Explain main steps to a program
    - Written exams
    - Surveillance audit
    - QA Manual review
    - Approval report and documentation

- Assess DRIs must take and pass two (2) DRI exams General Exam and Design Selection Exam
- Each company must have at least one (1) DRI
- An individual can be a DRI for one (1) location only

- Submit a written QA Manual
  - FM provides a list of items to address
  - You decide how your level of commitment
  - We don't tell you how to run your business
  - We review, comment and make suggestions
  - No minimum length or number of pages
  - FCIA has a template members can use

- Office and job-site audits
  - -Initial audit usually by your project engineer
  - -Review of documentation and material storage
  - -Not interested in financials
  - -Office and job-site at least annually
  - -Verify minimum two (2) years in firestopping business and adherence to QA Manual

- Issue documentation and listing
  - Approval report contains findings/requirements
  - Listing in the FM Approval Guide
  - Certificate of Compliance issued to the company
  - Certificate to each DRI

- Closed books
- No calculators or mfg's catalogs needed
- All questions are T/F and multiple choice
- 2 hrs 45 minutes to complete both exams
- Score of 80 needed on each exam

- The General Exam
  - About 35 questions on the MOP and FM Approval Std
  - Since it is closed book, questions are general in nature

#### The General Exam – examples

Which answer best describes Perimeter Fire Containment Systems?

a) They are typically non-rated walls

b) There is a void between the edge of the floor/ceiling (typically rated) and the interior face of the wall

c) The interior face of exposed framing requires some means of protection

d) All of the above

# The General Exam – examples True or False? Any material used as a packing material can remain in place after the installation is

remain in place after the installation is completed.

#### False

#### The General Exam – examples True or False?

Head of wall systems generally require that the entire gap be filled with a packing material before applying the sealant.

#### True

- Design Selection Exam
  - You do not need to remember any specific designs
  - Copies of the applicable design(s) are provided
  - Many different mfg's products are included
  - You are given a situation and asked to determine which design(s) can be used

#### Design Selection Exam – examples

- The concrete wall is 4 1/2 inches thick. The F rating needed is two (2) hours. The joint width is 3/4 inches. No movement capability or air leakage requirements have been specified. Which system(s) meet this criteria?
  - a) FF-S-0028 only
  - b) FF-S-0026 only
  - c) FF-S-0026 or FF-S-0028 can be selected
  - d) FF-S-0026, FF-S-0028 or FW-D-1012 can be selected
  - e) None of the configurations shown above can be used
  - Any guesses?
  - Why?

- Design Selection Exam
- Most of the problems aren't as tricky as the previous one but you will need to read them carefully.
- There are 5 problems each with 5 parts so each answer is worth 4 points.
- There are problems on Through Penetrations, Joints, Head of Wall and Perimeter Edge
- You need to know all these even if you make a business decision to only do some of these types of firestopping

- You must address just about everything you do and have a process for doing it.
- Management decides what level of quality a company will provide.
- There is a cost associated with a quality program.
- There is a cost associated with a lack of quality call backs, bad reputation, loss of projects.

- We don't tell you how to run your business!
- You tell us what you do.
- We'll audit you to make sure you're doing what you say you're doing.

- Management Organization
- Receiving Inspection
- Material Storage
- In-Process Controls
- Final Assembly and Test

- Assign a unique document name
- Assign a date of issue
- Show revision levels
- Number all pages and appendices
- Include a Table of Contents

- Non Conforming Materials
- Procurement and Supplier Control
- Design Selection
- Drawing and Document Control
- Corrective Action

- Measurement and Test Equipment
- Personnel Training and Certification
- Recordkeeping
- Miscellaneous

- An example Material Storage
- Basic Concept
- Temporary holding of raw materials
- Control of the environment (temperature, dry)
- Not to change the material in any way
- Adequate identification prevents damage, deterioration, loss and theft

- Make it available to all personnel
- Require all personnel to annually review the manual (and sign a statement acknowledging they have reviewed it and understand it)
- Conduct your own internal review don't count solely on outside organizations

- Support and commitment by upper management
- Written instructions addressing foreseeable events and situations
- Knowing that an ounce of prevention is worth a pound of cure

- Initial audit as part of the Approval
  - Office and job-site components
  - Review of records and facility
  - Compare your QA manual to what is actually being done
  - Conducted by your project engineer
  - Can take from 4 to 8 hours

- Office audit
  - Review one or more submittal packages
  - Examine material storage conditions
  - Review how design information is transferred to the jobsite (how does the installer know which design goes where)

- Job-site audit
  - Examine material storage
  - Review documentation on site
  - Witness several installations being done or conduct destruction examination on several items

#### Follow-up Surveillance Audits

- Conducted annually
- Done by an auditor from our Quality Dept
- Both office and job-site required
- Can be unannounced but most likely the auditor will call ahead and make sure the necessary people are available
- Similar to original audit
- Probably completed in 4 hrs or less

- Continued employment with the company
- Continuing education/ obtaining LUs
- Re-examination every three (3) years

- Continued knowledge and ability
- Satisfactory follow-up Surveillance Audits
- Employment of at least one (1) DRI

- Continued knowledge and ability
  - Satisfactory performance resulting from Surveillance Audits
  - Satisfactory performance of firestopping installed under this program

- Satisfactory follow-up Surveillance Audits
  - Office and job-site
  - Review of records and submittal packages
  - Storage and handling of materials
  - Handling non-conformances
  - Inspection by company personnel
  - Destructive examination at job-site
  - Labeling

- Employment of at least one (1) DRI
  - Verification of employment
  - DRI for only one (1) location
  - Continuing education/re-examination reminder
  - About 33% of contractors have more than one (1) DRI

- Continued employment with the company
  - Must remain employed with the company
  - Status does not transfer to a new employer
  - Active in position with responsibilities as a DRI

- Continuing education/ obtaining LUs
  - One (1) LU = one (1) hour of education or training
  - Attending FCIA conferences (12 LUs) each
  - Manufacturers training (varies on duration of training)
  - Webinars
  - Other educational opportunities
  - Don't mix up CEUs and LUs1 CEU = 8 Lus
  - CEU & LU definitions are in the FM Standard 4991.
  - CEU's are issued by certified organizations only.

- Re-examination every three (3) years
  - DRI is responsible for meeting the re-certification requirements.
  - Deadlines are either June 30<sup>th</sup> or December 31<sup>st</sup>
  - Written re-exam and 48 LUs are required
  - Obtain 72 LUs written exam is waived
  - < 48 LUs only option is to retake original exams
  - Updated DRI certificate issued

- $\ge 72$  LUs -> written examination is waived
- $-48 \le LUs < 72 LUs \rightarrow$  written re-examination is required
- < 48 LUs -> original (two-part) examination is required

#### **Questions?**

[INSERT SECURITY CLASSIFICATION IN SLIDE MASTER VIEW]